



Centrum stavebního inženýrství a.s. Praha
Centre of Building Construction Engineering Prague
Akreditované zkušební laboratoře, Autorizovaná osoba,
Notifikovaná osoba, Certifikační orgán
Accredited Test Laboratories, Authorised Body,
Notified Body, Certification Body
Pražská 16, 102 00 Praha 10



EC CERTIFICATE OF CONFORMITY

1390 – CPD – 0332/12/P

In compliance with Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (the Construction Products Directive or CPD), as later amended, it has been stated that the construction product

Factory made mineral wool products used for building equipment and industrial installations

(according to declaration list given in the annex to the certificate)

IZOTUB – circular insulation pipes without coat

IZOTUB AI – circular insulation pipes with reinforced Al-foil coat

placed on the market by : **IZOMAT Praha, spol. s r.o., IČO: 45242003**
Hroznova 491/4
118 00 Praha 1

and produced in the factory: **IZOMAT Praha, spol. s r.o.**
areál Drazdy, Zdiměřice 42
252 42 Zdiměřice

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body No.1390 - Centrum stavebního inženýrství a.s. - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control .

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

ČSN EN 14 303 : 2010
and Annex B and C of the standard ČSN EN 13 172 : 2009

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on **26. 03. 2012** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Notified Body 1390
Prague, 27. 03. 2012




Ing. Petr Kučera, Ph.D.
Deputy of Notified Body 1390



Centrum stavebního inženýrství a.s. Praha
Centre of Building Construction Engineering Prague

Akreditované zkušební laboratoře, Autorizovaná osoba,

Notifikovaná osoba, Certifikační orgán

Accredited Test Laboratories, Authorised Body,

Notified Body, Certification Body

Pražská 16, 102 00 Praha 10



Annex to the EC CERTIFICATE OF CONFORMITY 1390-CPD-0332/12/P

**The certificate covers the following products of IZOMAT Praha, spol. s r.o.,
site of production Drazdy, 252 42 Zdiměřice**

tab 1

<i>Trade mark</i>	<i>Thermal conductivity $W.m^{-1}.K^{-1}$</i>	<i>Reaction to fire</i>	<i>Type code in accordance with EN 14 303</i>
IZOTUB AI	see table No. 2	A2 _L -s1,d0	MW-EN-14 303-T ^{*)} -ST(+)-620-WS1-CL10
IZOTUB		A1 _L	MW-EN-14 303-T ^{*)} -ST(+)-620-WS1-CL10

*) in dependence on outside pipe diameter

T8 for Do < 150mm

T9 for Do ≥ 150 mm

tab 2

<i>t°C mean temperature</i>	<i>λ_D Thermal dependence of thermal conductivity $W.m^{-1}.K^{-1}$</i>						
	10	50	100	150	200	250	300
thermal conductivity $W.m^{-1}.K^{-1}$	0,040	0,044	0,055	0,068	0,087	0,110	0,136



Notified Body 1390

Prague, 27. 03. 2012


Ing. Petr Kučera, Ph.D.
Deputy of Notified Body 1390